

# Cramer

## Analytical Laboratory

# Chemical Report

1188 East Main Street, Grass Valley, CA 95945-5710 (530) 273-7284, FAX (530) 273-9507 E.L.A.P. Certification No. 1936

Donner Summit P.U.D.  
P.O. Box 610  
Soda Springs CA 95728

**Job Number:** 6090157  
**Date Reported:** 02/05/09  
**Date / Time Received:** 01/26/09 15:43  
**System Number:** 2910016

---

---

**Sample Number:** 6090157 - 1

**Sample Site:** Influent (24 hr composite)

**Date / Time Collected:** 01/26/09 8:15

**Sample Collected By:** K. Sullivan

Parameter	Analysis Result	Reporting Units	Analytical Method	Date of Analysis	Reporting Limit
5-Day Biochem. Oxygen Demand at 20°C	188	mg/L	SM 5210 B	01/28/2009	2
Total Suspended Solids	176	mg/L	SM(18) 2540C	01/27/2009	1

---

---

**Sample Number:** 6090157 - 2

**Sample Site:** Effluent (24 hr composite)

**Date / Time Collected:** 01/26/09 7:30

**Sample Collected By:** K. Sullivan

Parameter	Analysis Result	Reporting Units	Analytical Method	Date of Analysis	Reporting Limit
5-Day Biochem. Oxygen Demand at 20°C	2	mg/L	SM 5210 B	01/28/2009	2
Total Suspended Solids	4	mg/L	SM(18) 2540C	01/27/2009	1

---

---

**Sample Number:** 6090157 - 3

**Sample Site:** Effluent Grab

**Date / Time Collected:** 01/26/09 7:30

**Sample Collected By:** K. Sullivan

Parameter	Analysis Result	Reporting Units	Analytical Method	Date of Analysis	Reporting Limit
Ammonia as N	7.1	mg/L	SM(18) 4500 NH3	02/03/2009	0.1
Nitrate as N	1.78	mg/L	EPA 300.0	01/28/2009	0.1