

Donner Summit P.U.D.
P.O. Box 610
Soda Springs CA 95728

Job Number: 6090337
Date Reported: 03/16/09
Date / Time Received: 02/23/09 16:24
System Number: 2910016

Sample Number: 6090337 - 1

Sample Site: Influent (24 hr composite)

Date / Time Collected: 02/23/09 8:30

Sample Collected By: Jim King

Parameter	Analysis Result	Reporting Units	Analytical Method	Date of Analysis	Reporting Limit
5-Day Biochem. Oxygen Demand at 20°C	192	mg/L	SM 5210 B	02/25/2009	2
Total Suspended Solids	200	mg/L	SM(18) 2540C	02/27/2009	1

Sample Number: 6090337 - 2

Sample Site: Effluent (24 hr composite)

Date / Time Collected: 02/23/09 7:10

Sample Collected By: Jim King

Parameter	Analysis Result	Reporting Units	Analytical Method	Date of Analysis	Reporting Limit
5-Day Biochem. Oxygen Demand at 20°C	3	mg/L	SM 5210 B	02/25/2009	2
Total Suspended Solids	4	mg/L	SM(18) 2540C	02/27/2009	1

Sample Number: 6090337 - 3

Sample Site: Effluent Grab

Date / Time Collected: 02/23/09 7:10

Sample Collected By: Jim King

Parameter	Analysis Result	Reporting Units	Analytical Method	Date of Analysis	Reporting Limit
Ammonia as N	5.2	mg/L	SM(18) 4500 NH3	03/03/2009	0.1
Nitrate as N	3.00	mg/L	EPA 300.0	02/25/2009	0.1
Phosphate as P	1.84	mg/L	EPA 365.2	02/25/2009	0.01
Total Phosphorus as P, Persulfate-Acid Dgt	0.70	mg/L	SM(18) 4500 P	03/10/2009	0.01

Note: "ND" means "none detected" (ie, none was found in the sample at or above the reporting limit).

cc: Brentwood Inc.

Client Name: Donner Summit P.U.D.

Date Reported: 03/16/09

Job Number: 6090337

Sample Number: 6090337 - 4

Sample Site: R-1

Date / Time Collected: 02/23/09 9:10

Sample Collected By: Jim King

Parameter	Analysis Result	Reporting Units	Analytical Method	Date of Analysis	Reporting Limit
Nitrate as N	ND	mg/L	EPA 300.0	02/25/2009	0.1
Phosphate as P	ND	mg/L	EPA 365.2	02/25/2009	0.01
Total Phosphorus as P, Persulfate-Acid Dgt	0.03	mg/L	SM(18) 4500 P	03/10/2009	0.01

Sample Number: 6090337 - 5

Sample Site: R-2

Date / Time Collected: 02/23/09 9:20

Sample Collected By: Jim King

Parameter	Analysis Result	Reporting Units	Analytical Method	Date of Analysis	Reporting Limit
Nitrate as N	ND	mg/L	EPA 300.0	02/25/2009	0.1
Phosphate as P	0.028	mg/L	EPA 365.2	02/25/2009	0.01
Total Phosphorus as P, Persulfate-Acid Dgt	0.06	mg/L	SM(18) 4500 P	03/10/2009	0.01

Note: "ND" means "none detected" (ie, none was found in the sample at or above the reporting limit).

cc: Brentwood Inc.


Ken Neely

